

Security/Emergency Gate Submittal Guide

Online Application Information:

Submit applications at www.goodyearaz.gov/development

Application Type: Building Application

Project Type: Fire Protection Systems

Upload and Submit:

Checked files are the required files to submit with the application.

- Scaled Site Plan including:
 - Clear Width of All Drive Aisles
 - Add Note stating landscape cannot obstruct signage or pre-emption devices
 - Add Note state gate is able to be operated by one person
 - "No Parking" signage to be installed on gate
 - Manual Gates:
 - Provide Knox Padlock with double hasp so owner can place padlock on other side
 - Automatic Gates:
 - Show location of Control Pedestal – On Drivers Side – Minimum 10 feet from gate
 - Show Knox Key Switch to Be At Control Pedestal
 - Key Switch Mounting Height to be 66" Above Finished Grade
 - Approved Pre-emption Device to be Facing Gate Approach
 - "Fire Department Access" Signage to be Installed at Knox Key Switch
 - Gates to be Provided with Battery Backup
 - Gates to Open from Inside when Approached or Provide all Items Above

ATTENTION:

This submittal guide is a reference/resource for applicants to prepare for submitting an application. This document is not required to be included with your attachments.

Items checked on this guide should be uploaded in your attachments. Plan sets may be uploaded as multi-page PDFs.

If the box is not checked, these items are not required but may be included if needed and can be uploaded to your project as a "Supporting Document."

Fees Due:

Plan review and permit fees are paid at time of permit issuance.