


| | | | | | | | | |
|---------------|--------------|------------------|-----------------|------------------|------------------------------|--|------|---|
| NUMBER | | NOT REQ'D | NOT DONE | SATISFIED | IRRIGATION | | |  |
| | | | | | REVIEW # | | | |
| | | | | | BY | | DATE | |
| | ITEMS | | | | Location in Standards | | | |

| | | | | | |
|----|--|--------------------------|--------------------------|--------------------------|---|
| 1 | Review General & G&D Checklists | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 0.3 |
| 2 | RID Signature Required, Add RID Notes To Plans | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 0.2.3 |
| 3 | Scale 1"=20' Horizontal, 1"=2' Vertical (Same As Paving & Storm Drain Plans) | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 2.11.2(A.12) |
| 4 | Existing Irrigation Facilities To Remain In The Tract Or In R/W Must Be Tiled At 90° Angles With RGRCP | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 4.1.2(C.4) Sub Reg. 15-4-4(I) |
| 5 | Private Irrigation Facilities Must Be Located On Private Property | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 4.1.2(C.3) |
| 6 | Manholes Out Of Sidewalk Is Preferred, Adjust Rim To FG | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | |
| 7 | Ex. Utility Clearances Shown In Profile | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Per MAG |
| 8 | Top of pipe not in pavement structural section | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | |
| 9 | Add Note To Private LS Irrigation That Uses Non-Potable Reclaimed Water | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | NON-POTABLE IRRIGATION NOTE: "The Non-Potable Irrigation System Is Privately Owned And Maintained. The Engineer Is Responsible To Ensure That The Design Complies With All County And State Requirements. |
| 10 | Commercial Landscape Irrigation To Tie Into Project Mainline Or To A Separate LS Meter & Backflow | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | |
| 11 | Inspection Permit Required For Irrigation Constructed In Right-Of-Way & PUE. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | |
| 12 | See RID Guidelines For Their Requirements | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | |